

## Task Hazard Analysis (THA) Worksheet

(See [ES&H Manual Chapter 3210 Appendix T1](#)  
[Work Planning, Control, and Authorization Procedure](#))

Click  
For Word

<b>Author:</b>	Valery Kubarovsky	<b>Date:</b>	June 8, 2016	<b>Task #:</b> If applicable	
<b>Complete all information. Use as many sheets as necessary</b>					
<b>Task Title:</b>	Operation of RICH	<b>Task Location:</b>	Hall-B		
<b>Division:</b>	Physics	<b>Department:</b>	Hall-B	<b>Frequency of use:</b>	Daily
<b>Lead Worker:</b>	Valery Kubarovsky				
<b>Mitigation already in place:</b> <a href="#">Standard Protecting Measures</a> <a href="#">Work Control Documents</a>	Standard Hall-B protective measures and appropriate personal training including but not limited to RICH ESAD and RICH manual.				

Sequence of Task Steps	Task Steps/Potential Hazards	<a href="#">Consequence Level</a>	<a href="#">Probability Level</a>	<a href="#">Risk Code</a> (before mitigation)	Proposed Mitigation (Required for <a href="#">Risk Code</a> >2)	Safety Procedures/ Practices/Controls/Training	<a href="#">Risk Code</a> (after mitigation)
1	<ul style="list-style-type: none"> <li>Electrical shock from touching exposed wires or damage to MAPMTs if the enclosure is opened with HV on</li> </ul>	L	L	1	<ul style="list-style-type: none"> <li>Hardware enclosure door interlock</li> <li>Personal training, setting boundaries around equipment.</li> <li>Use Lock/Tag/try procedures</li> </ul>	<ul style="list-style-type: none"> <li>All maintenance and repair work inside RICH enclosure is done by trained personal with HV off, power supplies power cords unplugged and LTT devices applied.</li> <li>Interlock disables HV when enclosure is open.</li> <li>Interlock prevents energizing the detector if the door is open.</li> </ul>	Negligible

## Task Hazard Analysis (THA) Worksheet

(See [ES&H Manual Chapter 3210 Appendix T1](#)  
[Work Planning, Control, and Authorization Procedure](#))

Sequence of Task Steps	Task Steps/Potential Hazards	Consequence Level	Probability Level	Risk Code (before mitigation)	Proposed Mitigation (Required for Risk Code >2)	Safety Procedures/ Practices/Controls/Training	Risk Code (after mitigation)
2	<ul style="list-style-type: none"> <li>Heat buildup inside the RICH enclosure if cooling system is not running. This may cause damage to the experimental equipment</li> </ul>	H	L	3	<ul style="list-style-type: none"> <li>Air cooling system was chosen to remove heat from the detector</li> <li>Hardware cooling system interlock will turn off HV and LV systems and will prevent to switch ON HV and LV if the cooling system is OFF.</li> <li>Temperature interlock will switch off HV and LV systems</li> </ul>	<ul style="list-style-type: none"> <li>The air cooling system will monitor key detector parameters.</li> <li>If the monitored signals are out of pre-programmed limits, the air cooling shuts off HV and LV.</li> <li>Interlock prevents energizing the detector if the cooling system is off.</li> </ul> <p>The signals monitored for air cooling include:</p> <ol style="list-style-type: none"> <li>Air flow</li> <li>Pressure inside the air tank</li> <li>Air compressor power status</li> <li>Temperature inside the detector enclosure</li> </ol>	

## Task Hazard Analysis (THA) Worksheet

(See [ES&H Manual Chapter 3210 Appendix T1](#)  
[Work Planning, Control, and Authorization Procedure](#))

Sequence of Task Steps	Task Steps/Potential Hazards	Consequence Level	Probability Level	Risk Code (before mitigation)	Proposed Mitigation (Required for Risk Code >2)	Safety Procedures/ Practices/Controls/Training	Risk Code (after mitigation)
3	<ul style="list-style-type: none"> <li>The degradation of aerogel properties due to the uncontrolled humidity in the experimental hall</li> </ul>	L	L	1	<ul style="list-style-type: none"> <li>The nitrogen purge gas system is developed to flow dry gas and preserve aerogel optical performance</li> </ul>	<ul style="list-style-type: none"> <li>The nitrogen flow and detector internal humidity will be constantly monitored.</li> <li>The nitrogen purge system sets off an alarm in case the key parameters (nitrogen flow and detector internal humidity) is outside of pre-programmed limits.</li> </ul>	

Highest Risk Code before Mitigation:

3

Highest Risk Code after Mitigation:

1

When completed, if the analysis indicates that the Risk Code before mitigation for any steps is “medium” or higher ( $RC \geq 3$ ), then a formal [Work Control Document](#) (WCD) is developed for the task. Attach this completed Task Hazard Analysis Worksheet. Have the package reviewed and approved prior to beginning work. (See [ES&H Manual Chapter 3310 Operational Safety Procedure Program](#).)

# Task Hazard Analysis (THA) Worksheet

(See [ES&H Manual Chapter 3210 Appendix T1](#)  
[Work Planning, Control, and Authorization Procedure](#))

## Form Revision Summary

**Periodic Review – 08/13/15** – No changes per TPOC

**Revision 0.1 – 06/19/12** - Triennial Review. Update to format.

**Revision 0.0 – 10/05/09** – Written to document current laboratory operational procedure.

ISSUING AUTHORITY	TECHNICAL POINT-OF-CONTACT	APPROVAL DATE	REVIEW DATE	REV.
ESH&Q Division	<a href="#">Harry Fanning</a>	08/13/15	08/13/18	0.1

*This document is controlled as an on line file. It may be printed but the print copy is not a controlled document. It is the user's responsibility to ensure that the document is the same revision as the current on line file. This copy was printed on 6/8/2016.*