

HALL C PLC TASKS REPORT (10/11/2018 – 10/17/2018)

- Current Loop Regulation routine tested using DSG-PLC and Danfysik Python simulator.
 - ★ Code was modified to meet Hall C specifications.
 - ★ Python simulator will ramp up to MOL value (user-input current plus a user-set overshoot), but will not drop back down to initial requested value, as it should.