



ENVIRONMENT, SAFETY, HEALTH, AND QUALITY DIVISION

# Seismic Design Specification for Buildings, Structures, Equipment, and Systems: 2014

SLAC-I-720-0A24E-001-R004

8 July 2014

# Publication Data

This document was developed by the Seismic Design program and published by ESHQ Publishing.

Document Title: Seismic Design Specification for Buildings, Structures, Equipment, and Systems: 2014

Original Publication Date: 4 August 1999

Revision Date: 8 July 2014

Effective Date: 8 July 2014

Department: Environment, Safety, Health, and Quality Division

Document Number: SLAC-I-720-0A24E-001-R004

ProductID: [59](#) | RevisionID: [1647](#)

URL: <http://www-group.slac.stanford.edu/esh/documents/techbas/seismic.pdf>

Prepared for the United States Department of Energy under contract DE-AC02-76SF00515

*Note     The technical content of this revision was authored by civil and structural engineers: Felix K. Adikara, PE, Infrastructure Engineering Division, and Michael Loomis, SE, consultant to the Building Inspection Office, ESHQ Division. The content was reviewed by*

*Scott DeBarger, ME, Accelerator Directorate*

*Ken Fouts, SLAC chief engineer*

*Ernie T. Gomes, Jr, manager, Building Inspection Office, ESHQ Division*

*Lori Jean Plummer, PE, Accelerator Directorate*

*Javier A. Sevilla, PE, manager, Infrastructure Engineering*

*Shane Wells, PE, Major Capital Projects*

# Executive Summary

This document is intended to provide an overview of the requirements for seismic analysis and design of buildings, structures, equipment, and systems that will be constructed and installed at SLAC National Accelerator Laboratory.

SLAC will use the 2013 *California Building Code (CBC)* for structural design criteria.



# Contents

Publication Data

Executive Summary

Contents	i
1 General Design Requirements	1
1.1 Design Guidance	1
1.2 Modular / Portable Buildings	2
1.3 Nonstructural Components	2
2 Programmatic / Experimental Equipment Design Requirements	2
3 Approved Concrete Anchors	3
4 Special Design Requirements	4
4.1 Determination and Approval	4
5 Seismic Design Map	5



# 1 General Design Requirements

SLAC will use the 2013 *California Building Code (CBC)* for structural design criteria.<sup>1</sup>

The 2013 CBC adjusts the level of design based on risk categories from I to IV. Most projects at SLAC will be Risk Category II, which provides life safety seismic performance. There are a few exceptions to this risk category, which are clearly identified in the building code. These exceptions include assembly occupancies where more than 300 people congregate (Risk Category III) and essential facilities such as the fire station and emergency operations centers (Risk Category IV), requiring continued operation during and/or after an earthquake.

## 1.1 Design Guidance

In order to facilitate the process of designing structures and equipment anchorage, the following issues should be considered when designing for resistance to seismic loads:

- Site-specific seismic criteria may be based on values determined in accordance with ASCE 7-10<sup>2</sup> as amended by the 2013 CBC, Chapter 16. As an alternative, the seismic criteria may be based on the worst case values shown in Section 5 of this document for the location of the proposed work.
- For all anchors embedded into concrete that resist seismic loading, the cracked concrete provisions of ACI 318-11<sup>3</sup>, Appendix D, as amended by 2013 CBC, Sections 1905.1.9 and 1909.1, must be considered.
  - Post-installed anchors installed into hardened concrete (such as epoxy or expansion anchors) must be designed and installed in accordance with the same cracked concrete provisions using the procedures summarized by the manufacturer’s approved ICC-ES report.<sup>4</sup> Additional information on post-installed anchors can be found in Section 4 of this document.
  - Anchor design must be governed by ductile yielding of a steel element (anchor or attachment), unless the exceptions of 2013 CBC, Section 1905.1.9 are met. See ACI 318-11, Section D.3.3.4, D.3.3.5, and D.3.3.6 for design requirements.

---

1 The *California Building Code (CBC)* is codified as Title 24, *California Code of Regulations*, “California Building Standards Code”, Part 2, “California Building Code” ([24 CCR Part 2](#))

2 American Society of Civil Engineers (ASCE) 7-10, “Minimum Design Loads for Buildings and Other Structures, including Supplements No. 1 and 2” ([ASCE 7-10](#))

For a list of ASCE standards and errata, see the ASCE Structural Engineering Institute, <http://content.seinstitute.org/>.

3 American Concrete Institute (ACI) 318-11, “Building Code Requirements for Structural Concrete and Commentary” ([ACI 318-11](#))

For a list of ACI standards, see the ACI Bookstore, <http://www.concrete.org/bookstorenet/default.aspx>.

4 International Code Council (ICC) Evaluation Report (ER)

For a list of ICC ERs, see “ICC-ES: Evaluation Reports”, [http://www.icc-es.org/Evaluation\\_Reports/index.shtml](http://www.icc-es.org/Evaluation_Reports/index.shtml).

- Any questions about correct implementation of code requirements for seismic design should be directed to the Building Inspection Office (BIO) or structural authority having jurisdiction (AHJ).

## 1.2 Modular / Portable Buildings

Modular/portable buildings that are permanently installed must be designed to meet the same criteria as those installed at California public schools K-12 and anchored to meet the criteria for Risk Category II.

## 1.3 Nonstructural Components

In compliance with the 2013 CBC, nonstructural components (including architectural, mechanical, electrical, and plumbing equipment) and their supports and attachments that are permanently attached to a structure must be designed and constructed to resist the effects of the earthquake motions in accordance with the code. Refer to ASCE 7-10, Chapter 13, for specific requirements.

ASCE 7-10 exemptions that apply at SLAC are the following. Note that these exemptions do not require a designed anchorage, but all equipment still must be secured in place as directed by code:

- Mechanical and electrical components with Importance Factor,  $I_p$ , equal to 1.0 and both of the following conditions apply:
  - Flexible connections between the components and associated ductwork, piping, and conduit are provided.
  - Components are mounted at four feet or less above a floor level and weigh 400 pounds or less.
- Mechanical and electrical components with Importance Factor,  $I_p$ , equal to 1.0 and both of the following conditions apply:
  - Flexible connections between the components and associated ductwork, piping, and conduit are provided.
  - And the components weigh 20 pounds or less or, for distribution systems, weighing five pounds per foot or less.

# 2 Programmatic / Experimental Equipment Design Requirements

The following programmatic/experimental equipment and structures must be designed and constructed to resist the effects of earthquake motions in a manner that ensures life safety:

- Any structure that personnel can enter, such as radiation hatches and shielding structures:  
The seismic design criteria will be met by using the 2013 CBC for seismic design (risk category as appropriate per the 2013 CBC).
- Any experimental equipment that weighs more than 400 pounds:



The seismic design criteria will be met by using the 2013 CBC for seismic design. For ground-mounted experimental equipment, the alternate method given below may be used with the following strength design load combinations (Note: this alternate method is allowed to be used only for equipment assigned to Risk Category II of ASCE 7-10):

- $(1.6) \times \text{Dead Load} + E$
- $(0.5) \times \text{Dead Load} + E$

Where “dead load” includes operating live load (where applicable) and “E” = effects of horizontal seismic forces. The seismic loading is analyzed as an inertial force, so the effects of the horizontal acceleration may include overturning. Refer to Table 1.

**Table 1** Horizontal Earthquake Acceleration Values for Experimental Equipment

Horizontal Earthquake Acceleration		
280 and West, incl. Sector 25	East of 280	Experimental Equipment Structure Type Similar to the Following
0.80 g	0.70 g	<ul style="list-style-type: none"> <li>▪ Elevated tanks, vessels, bins, or hoppers on symmetrically braced legs</li> <li>▪ Horizontal, saddle supported welded steel vessels</li> <li>▪ Flat-bottom ground-supported tanks (steel or fiber reinforced plastic)</li> <li>▪ Steel and reinforced concrete distributed mass cantilever structures</li> <li>▪ Components and systems isolated using neoprene elements</li> </ul>
01.00 g	0.85 g	<ul style="list-style-type: none"> <li>▪ Elevated tanks, vessels, bins, or hoppers on unbraced or asymmetrically braced legs</li> <li>▪ Inverted pendulum type structure (except elevated tanks, vessels, bins or hoppers)</li> <li>▪ Spring isolated components and systems</li> </ul>

Note: consideration should be given for equipment that may be relocated or installed in multiple locations to use the higher acceleration from the table above. Contact the Building Inspection Office if you have any questions about what acceleration to use.

In all cases, the anchors and the adequacy of the anchorage to support the design loads must be design-reviewed by a California-licensed civil engineer.

### 3 Approved Concrete Anchors

Post-installed anchors (anchors installed into existing hardened concrete) must be approved to resist seismic loads and have a current ICC-ES report. Where anchorage conditions require an engineered design, it must be performed in accordance with the ICC-ES report and the cracked concrete provisions of ACI 318-11, Appendix D.

Some commonly used, approved anchors are listed below (intended as examples, not an all inclusive list):

- Epoxy anchors      Hilti HIT-RE 500SD (ICC ESR No. 2322)  
                             Simpson SET-XP (ICC ESR No. 2508)
- Expansion anchors      Hilti Kwik-Bolt TZ (ICC ESR No. 1917)  
                             Simpson Strong-Bolt (ICC ESR No. 1771)

## 4 Special Design Requirements

There is the possibility that a project at SLAC will require exceptional seismic performance (higher than would be required per the building code), due to special importance to mission or extreme safety hazard. SLAC is subject to Department of Energy Standard DOE-STD-1020-2012<sup>5</sup> as a non-nuclear facility under Section 2.1 of that standard. Projects that contain significant chemical or toxicological hazards must be designed in accordance with DOE-STD-1020-2012, Section 3, “Criteria and Guidelines for Seismic Design”.

For these projects, the structural design must use the importance factors for Risk Category IV. Only the importance factor is changed; the building code chapters used for structural design would be those that are normally used for the particular structure. Note that for some limit states, DOE-STD-1020-2012 Table 3-1 requires substituting a Response Modification Coefficient “R” that is reduced from the ASCE 7-10 value.

The imposition of Risk Category IV has a significant design and cost impact, requiring seismic testing for the internal parts of equipment such as electrical panel boards, HVAC units, and racks, in addition to stringent building structural requirements. This category is intended to apply only to those structures and systems that must be fully operable during and immediately after a design-level earthquake.

### 4.1 Determination and Approval

The decision to identify a project as being critical to safety or mission and assign it to Risk Category IV requires the written approval of the laboratory director. This determination must be made and properly documented, during the initiation and conceptual phase of the project, using the policy and guidelines from DOE-STD-1020-2012.

---

5 Department of Energy Standard 1020-2012, “Natural Phenomena Hazards Analysis and Design Criteria for DOE Facilities” ([DOE-STD-1020-2012](#))

## 5 Seismic Design Map




Figure 1 Proximity to San Andreas Fault



Figure 2 SLAC Map

Table 2 Seismic Ground Motion Values

Location	$S_s$	$S_1$	$S_{DS}$	$S_{D1}$	SDC R.C. I/II	SDC R.C. III	SDC R.C. IV
1	2.166	0.917	1.444	0.917	E	E	F
2	2.170	0.923	1.447	0.923	E	E	F
3	2.267	0.952	1.512	0.952	E	E	F
4	2.358	0.977	1.572	0.977	E	E	F
5	2.563	1.014	1.709	1.014	E	E	F
6	2.403	0.973	1.602	0.973	E	E	F
7	2.483	0.991	1.655	0.991	E	E	F
8	2.613	1.022	1.742	1.022	E	E	F
9	2.745	1.055	1.830	1.055	E	E	F
10	2.840	1.094	1.893	1.094	E	E	F
11	2.897	1.132	1.931	1.132	E	E	F
12	2.946	1.164	1.964	1.164	E	E	F
13	3.001	1.198	2.000	1.198	E	E	F
14	2.315	0.958	1.543	0.958	E	E	F

\*The  $S_{DS}$  values are based on site class D