



## Marine Chemist Service, Inc.

11850 TUG BOAT LANE  
NEWPORT NEWS, VA 23606-2527  
TEL: (757) 873-0933 · NORFOLK (757) 640-1122  
FAX: (757) 873-1074 · NORFOLK (757) 625-5696  
[www.MarineChemist.com](http://www.MarineChemist.com)

Credentials  
Accreditation  
Accreditation

Agency  
ABS  
NIST  
AIHA

Program (Scope)  
(Hull Thickness)  
NVLAP  
Bulk Asbestos (PLM)  
ELLAP (Lead)  
(Paint, Soil, Wipe & Air)  
EMLAP  
Air (Direct Examination)  
IHLAP  
Asbestos (PCM)  
Dust (Gravimetry)  
Metals (AA)  
Resin

Approval

DOD-  
US Navy

Laboratory accreditations cover only to the scopes listed above.

AIHA Laboratory No: 100551

NVLAP Lab Code: 200628-0

Virginia Asbestos Lab License No: 3333 000004

Jefferson Laboratories  
Attn: Jen Williams  
12000 Jefferson Avenue  
Newport News, VA 23606

MCS Report No.: 0094163  
Report Date: 05/22/2012  
MCS Job No.:  
Customer PO No.:

Date Sampled: 05/17/2012  
Sampled By: Customer  
Job Location: TED

Date Received: 05/17/2012  
Received By: JNP  
Sample Matrix: DRINKING WATER

## REPORT OF ANALYSIS

MCS Sample No. Field Sample ID	Sample Location Description	Analysis	Result	Reporting Limit	Units	Method	Analysis Date	Analyst
0094163-001 12JW100	Breakroom #1511, Left Faucet	Coliform- Colilert	Absent	P/A	Pres/Abs	Colilert	05/17/2012	ECR
		Heterotrophic Plate Count	<1	1	cfu/ml	SM 9215B Ed. 20	05/17/2012	ECR
0094163-002 12JW101	Breakroom #1511, Right Faucet	Coliform- Colilert	Absent	P/A	Pres/Abs	Colilert	05/17/2012	ECR
		Heterotrophic Plate Count	<1	1	cfu/ml	SM 9215B Ed. 20	05/17/2012	ECR
0094163-003 12JW102	Women's Restroom Upstairs #2557, Right Faucet	Coliform- Colilert	Absent	P/A	Pres/Abs	Colilert	05/17/2012	ECR
		Heterotrophic Plate Count	98	1	cfu/ml	SM 9215B Ed. 20	05/17/2012	ECR
0094163-004 12JW103	Women's Restroom Downstairs, #1514	Coliform- Colilert	Absent	P/A	Pres/Abs	Colilert	05/17/2012	ECR
		Heterotrophic Plate Count	110	1	cfu/ml	SM 9215B Ed. 20	05/17/2012	ECR

*Bharati Lakshmi*

Approved Signatory - Dr. Bharati Lakshmi, Ph.D  
Laboratory Supervisor

- \* MCS, Inc. can not attest to nor be held responsible for the proper collection of samples and/or accuracy of the sample information provided by customers for samples not collected by MCS, Inc.
- \* Test report relates only to the items tested.
- \* This report shall not be reproduced, except in full, without the written approval of this laboratory.
- \* For all laboratory test results assume two significant figures.
- \* Laboratory test results are not corrected for blank values.
- \* All laboratory test results meet the applicable quality control requirements unless otherwise mentioned.
- \* The Report includes Chain of Custody and if applicable TWA Table.

**NOTE:** Analysis performed at James R. Reed & Associates, Newport News, VA (VELAP# 460013 and EPA# 00015).  
Sample Numbers 12-07741 to 12-07744.

SAMPLING ANALYSIS, CONSULTING, WRITTEN PLANS / SPECIFICATIONS AND TRAINING CLASSES  
SPECIALIZING IN ASBESTOS, LEAD, PCB, HAZARDOUS WASTE, MOULD  
CERTIFIED MARINE CHEMIST AND INDUSTRIAL HYGIENIST INSPECTIONS  
BURNING NOISE ID & SECURITY DEVICE, NON-DESTRUCTIVE TESTING  
NON-SPARKING SAFETY TOOLS, VENTILATION SALES

